

TECHNICIAN'S CHECKLIST
SECTION 543
ASPHALT CURING SEAL

PROJECT: _____

REVIEW DATE: _____

TECHNICIAN: _____

REVIEWER: _____

ACTION	YES	NO	N/A	COMMENTS
Study Specifications, plans, and Special Provisions.				
Ensure that the finished stabilized layer or base is kept continuously moist until the asphalt curing seal is placed.				
Ensure that the asphalt curing seal is applied within 24 hours and at the manufacturer's recommended temperature after completing the stabilization.				
Make sure that the curing seal was applied at the rate established by the Engineer.				
Monitor the temperature to ensure the requirements for the seven-day curing are met.				
Ensure that the Contractor protects areas to be crossed by traffic by using blotting sand.				
Record in the diary all conversations, observations, spot checks made, and work performed.				